



Test Certificates for Single Family Dwellings

No.: GAS-02
Date: 1991-05-29
Revised: 2019-05-13

Purpose:

- To clarify the information required for air test certificates.

Background:

- Gas regulations provide for the acceptance of an air test certificate from a qualified gas fitter for gas installations in single family dwellings. FortisBC does not identify the pressure of gas supply at a meter, therefore, we request this information from the licence contractor.

Implementation:

- An air test certificate must be submitted to our office for all above ground gas piping installed in a single family dwelling prior to final approval.
- The information provided on the certificate must include: permit number, project address, test details, gas fitter's name (printed), and gas fitter's certification number.
- In addition to the general information noted above, the actual delivered pressure at the meter outlet is required. Space is provided on the test certificate for the actual delivered pressure.
- Should you have any questions, comments, or suggestions concerning this bulletin, please reference the Bulletin Number and email building@richmond.ca or call the Building Approvals General Inquiries line at 604-276-4118.